



Royalite Manufacturing Inc.
www.royalite-mfg.com

1055 Terminal Way, San Carlos, Ca. 94070
(650) 637-1440, Fax (650) 673-9770

***Subject: Code Compliance Evaluation
Royalite Residential Series Acrylic Dome
and Single-lite Glass Skylights***

The Royalite Residential Series Acrylic Dome and Single-lite Glass Skylights meet the Structural loading requirements of the 2013 California Building Code (CBC) and the 2012 International Building Code.

I have investigated the status of the Royalite Residential Series Skylights as compared with the requirements of American Architectural Manufacturer's Association specification (AAMA/WDMA/CSA 101/I.S.2/A440-08) which is cited in the 2013 CBC.

The specific requirements for materials, installation and allowable loads called for are acceptable under the current codes. The Royalite products meet or exceed the AAMA/WDMA/CSA 101/I.S.2/A440 design requirements for positive and negative design loads. The fixed units exceed the loading requirements of Performance Class CW (40psf) and the operable units exceed the requirements of Performance Class R (25psf).

Michael "Tony" Regan
Structural Engineer
10580 N. McCarran Blvd. #115-181
Reno, NV. 89503
(775) 741-2568
tgregan@aol.com

